

## **NORTH BALDWIN UTILITIES**

### **SANITARY SEWER SERVICE INSTALLATION GUIDANCE**

- From Property Line to Within Five (5) Feet of Structure -

**Effective June 30, 2008**

---

Upon payment of requisite fees to North Baldwin Utilities (NBU) and receipt of written authorization to establish a connection to the NBU sewer system, the Property Owner / Installer shall construct such connection in strict adherence with the following requirements and protocols.

1. All pipe and fittings used in constructing the connection shall be of highest quality and in good merchantable condition. Pipe and fittings shall be of Schedule 40 PVC with solvent weld joints.
2. Sewer service line shall exhibit a continuous and uniform fall toward the sewer main of not less than  $\frac{1}{4}$ " per foot.
3. At the point of connection of the sewer service to the sewer lateral end, and at no greater than 50-foot intervals along its length, an acceptable at-grade clean-out shall be provided. The clean-out assembly at the point of connection to the lateral end shall be secured at grade by means of a concrete-encased cast iron box, with cast iron cover, provided by NBU. All other clean-out assemblies shall be secured at-grade and terminated using watertight, removable caps.
4. Prior to backfill of service line trench, NBU shall be notified at 251/580-1626 to schedule an inspection and shall be afforded reasonable opportunity to observe the assembled work. NBU may require demonstration of the attainment of positive fall toward the sewer main.
5. Upon completion of all work, NBU shall be notified at 251/580-1626 and afforded opportunity to observe the completed work.

The Property Owner / Installer is encouraged to contact NBU should there be any questions or should further guidance be desired.